

Government of Bihar
Public Health Division Muzaffarpur
Water Quality Testing Report


Received Sample on date : 18.12.2023


District- Muzaffarpur				Testing date - 18.12.2023												
SL. No.	Block	Location of Source	Type of Source	Sample Collected by : School Staff												
				Parameters tested												
				pH	Turbidity	Total hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic	Total Coll.
1	Mushahri	Lyceum International School, Mithanpura Lala	Boring water	-	1	264	72.8	20	30	304	0.18	3.20	8	0.74	-	< 1.1
Desirable Unit				6.5 - 8.5	1	200	75	30	250	200	0.3 mg/l	45 mg/l	200	1.00	0.01 mg/l	-
Maximum Permissible limit in absence of alternate source				NR	5 NTU	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	1 mg/l	NR	400 mg/l	1.5 mg/l	NR	-

Memo No. - 3832 Muzaffarpur, Dated - 20/12/2023

Copy to Principal Lyceum International School, Mithanpura Lala, Muzaffarpur to inform regarding reference to his letter No. - LIS/272/23

Dated :- 18/12/2023,


20/12/23
Lab Assistant


Chemist


Assistant Engineer
P.H. Division, Muzaffarpur
ASSISTANT ENGINEER
P^H Division
Muzaffarpur